

CLEAN AGENT

## Clean Agent Fire Extinguisher (SS Body)

**2 kg**

- ISI marked · IS 15683:2018
- 5-year warranty
- Fire classes: A, B, C and electrical
- Stainless steel · data centres, hospitals

**A**

Wood, paper, cloth

**B**

Oil, petrol, paint

**C**

LPG, gas

**Electrical**

### TECHNICAL SPECIFICATIONS

| GENERAL             |                                      | PERFORMANCE           |                                                |
|---------------------|--------------------------------------|-----------------------|------------------------------------------------|
| Capacity            | 2 kg                                 | Throw range           | 2–4 m                                          |
| Type                | Portable, stored pressure (nitrogen) | Operating temperature | –30 to +60 °C                                  |
| Extinguishing agent | Clean agent: HFC-227ea / FK-5-1-12   | BUILD                 |                                                |
| Expelling agent     | Nitrogen (stored pressure)           | Body                  | AISI 304 / 316 stainless steel, polished       |
| Fire classes        | A, B, C and electrical               | Valve                 | Forged chrome-plated brass or SS, squeeze grip |
| Fire rating         | 1A:21B                               | SIZE & WEIGHT         |                                                |
| IS standard         | IS 15683:2018                        | Height                | 440 mm (approx.)                               |
| Approvals           | BIS (ISI mark)                       | Diameter              | 110 ± 5 mm                                     |
| Warranty            | 5 years                              | Weight when full      | 3.6 kg                                         |
| PERFORMANCE         |                                      | Empty weight          | 1.6 kg                                         |
| Working pressure    | 15 bar (at 27 °C)                    | Shipping weight       | 4.0 kg                                         |
| Test pressure       | 30 bar (hydrostatic)                 | IN THE BOX            |                                                |
| Discharge time      | 9–15 sec                             | In the box            | Vehicle / wall bracket                         |
| Discharge           | 96%                                  | SERVICE               |                                                |
|                     |                                      | Maintenance           | IS 2190                                        |

#### How to use: P.A.S.S.

1. **Pull** the safety pin
2. **Aim** at the base of the fire
3. **Squeeze** the handle
4. **Sweep** side to side

#### Care & service

Check it every month: gauge in the green zone, pin and seal in place, nothing blocking it. Get it serviced as per IS 2190 and refilled after any use. FIRENET does refilling, hydro testing and AMC in Pune & PCMC.